Environmental Protection Agency

§63.11116 Requirements for facilities with monthly throughput of less than 10,000 gallons of gasoline.

- (a) You must not allow gasoline to be handled in a manner that would result in vapor releases to the atmosphere for extended periods of time. Measures to be taken include, but are not limited to, the following:
 - (1) Minimize gasoline spills;
- (2) Clean up spills as expeditiously as practicable;
- (3) Cover all open gasoline containers and all gasoline storage tank fill-pipes with a gasketed seal when not in use;
- (4) Minimize gasoline sent to open waste collection systems that collect and transport gasoline to reclamation and recycling devices, such as oil/water separators.
- (b) You are not required to submit notifications or reports as specified in §63.11125, §63.11126, or subpart A of this part, but you must have records available within 24 hours of a request by the Administrator to document your gasoline throughput.
- (c) You must comply with the requirements of this subpart by the applicable dates specified in §63.11113.
- (d) Portable gasoline containers that meet the requirements of 40 CFR part 59, subpart F, are considered acceptable for compliance with paragraph (a)(3) of this section.

 $[73\ {\rm FR}\ 1945,\ {\rm Jan.}\ 10,\ 2008,\ {\rm as}\ {\rm amended}\ {\rm at}\ 76\ {\rm FR}\ 4182,\ {\rm Jan.}\ 24,\ 2011]$

§ 63.11117 Requirements for facilities with monthly throughput of 10,000 gallons of gasoline or more.

- (a) You must comply with the requirements in section §63.11116(a).
- (b) Except as specified in paragraph (c) of this section, you must only load gasoline into storage tanks at your facility by utilizing submerged filling, as defined in §63.11132, and as specified in paragraphs (b)(1), (b)(2), or (b)(3) of this section. The applicable distances in paragraphs (b)(1) and (2) shall be measured from the point in the opening of the submerged fill pipe that is the greatest distance from the bottom of the storage tank.
- (1) Submerged fill pipes installed on or before November 9, 2006, must be no more than 12 inches from the bottom of the tank.

- (2) Submerged fill pipes installed after November 9, 2006, must be no more than 6 inches from the bottom of the tank.
- (3) Submerged fill pipes not meeting the specifications of paragraphs (b)(1) or (b)(2) of this section are allowed if the owner or operator can demonstrate that the liquid level in the tank is always above the entire opening of the fill pipe. Documentation providing such demonstration must be made available for inspection by the Administrator's delegated representative during the course of a site visit.
- (c) Gasoline storage tanks with a capacity of less than 250 gallons are not required to comply with the submerged fill requirements in paragraph (b) of this section, but must comply only with all of the requirements in §63.11116.
- (d) You must have records available within 24 hours of a request by the Administrator to document your gasoline throughput.
- (e) You must submit the applicable notifications as required under §63.11124(a).
- (f) You must comply with the requirements of this subpart by the applicable dates contained in §63.11113.

[73 FR 1945, Jan. 10, 2008, as amended at 73 FR 12276, Mar. 7, 2008; 76 FR 4182, Jan. 24, 2011]

§ 63.11118 Requirements for facilities with monthly throughput of 100,000 gallons of gasoline or more.

- (a) You must comply with the requirements in §§63.11116(a) and 63.11117(b).
- (b) Except as provided in paragraph (c) of this section, you must meet the requirements in either paragraph (b)(1) or paragraph (b)(2) of this section.
- (1) Each management practice in Table 1 to this subpart that applies to your GDF.
- (2) If, prior to January 10, 2008, you satisfy the requirements in both paragraphs (b)(2)(i) and (ii) of this section, you will be deemed in compliance with this subsection.
- (i) You operate a vapor balance system at your GDF that meets the requirements of either paragraph (b)(2)(i)(A) or paragraph (b)(2)(i)(B) of this section.

§63.11120

- (A) Achieves emissions reduction of at least 90 percent.
- (B) Operates using management practices at least as stringent as those in Table 1 to this subpart.
- (ii) Your gasoline dispensing facility is in compliance with an enforceable State, local, or tribal rule or permit that contains requirements of either paragraph (b)(2)(i)(A) or paragraph (b)(2)(i)(B) of this section.
- (c) The emission sources listed in paragraphs (c)(1) through (3) of this section are not required to comply with the control requirements in paragraph (b) of this section, but must comply with the requirements in §63.11117.
- (1) Gasoline storage tanks with a capacity of less than 250 gallons that are constructed after January 10, 2008.
- (2) Gasoline storage tanks with a capacity of less than 2,000 gallons that were constructed before January 10, 2008.
- (3) Gasoline storage tanks equipped with floating roofs, or the equivalent.
- (d) Cargo tanks unloading at GDF must comply with the management practices in Table 2 to this subpart.
- (e) You must comply with the applicable testing requirements contained in §63.11120.
- (f) You must submit the applicable notifications as required under §63.11124.
- (g) You must keep records and submit reports as specified in §§ 63.11125 and 63.11126.
- (h) You must comply with the requirements of this subpart by the applicable dates contained in §63.11113.

[73 FR 1945, Jan. 10, 2008, as amended at 73 FR 12276, Mar. 7, 2008]

TESTING AND MONITORING REQUIREMENTS

§ 63.11120 What testing and monitoring requirements must I meet?

- (a) Each owner or operator, at the time of installation, as specified in $\S 63.11113(e)$, of a vapor balance system required under $\S 63.11118(b)(1)$, and every 3 years thereafter, must comply with the requirements in paragraphs (a)(1) and (2) of this section.
- (1) You must demonstrate compliance with the leak rate and cracking pressure requirements, specified in

- item 1(g) of Table 1 to this subpart, for pressure-vacuum vent valves installed on your gasoline storage tanks using the test methods identified in paragraph (a)(1)(i) or paragraph (a)(1)(ii) of this section.
- (i) California Air Resources Board Vapor Recovery Test Procedure TP– 201.1E,—Leak Rate and Cracking Pressure of Pressure/Vacuum Vent Valves, adopted October 8, 2003 (incorporated by reference, see §63.14).
- (ii) Use alternative test methods and procedures in accordance with the alternative test method requirements in §63.7(f).
- (2) You must demonstrate compliance with the static pressure performance requirement specified in item 1(h) of Table 1 to this subpart for your vapor balance system by conducting a static pressure test on your gasoline storage tanks using the test methods identified in paragraphs (a)(2)(i), (a)(2)(ii), or (a)(2)(iii) of this section.
- (i) California Air Resources Board Vapor Recovery Test Procedure TP– 201.3,—Determination of 2-Inch WC Static Pressure Performance of Vapor Recovery Systems of Dispensing Facilities, adopted April 12, 1996, and amended March 17, 1999 (incorporated by reference, see §63.14).
- (ii) Use alternative test methods and procedures in accordance with the alternative test method requirements in §63.7(f).
- (iii) Bay Area Air Quality Management District Source Test Procedure ST-30—Static Pressure Integrity Test—Underground Storage Tanks, adopted November 30, 1983, and amended December 21, 1994 (incorporated by reference, see §63.14).
- (b) Each owner or operator choosing, under the provisions of §63.6(g), to use a vapor balance system other than that described in Table 1 to this subpart must demonstrate to the Administrator or delegated authority under paragraph §63.11131(a) of this subpart, the equivalency of their vapor balance system to that described in Table 1 to this subpart using the procedures specified in paragraphs (b)(1) through (3) of this section.
- (1) You must demonstrate initial compliance by conducting an initial performance test on the vapor balance